



QUOTATION INQUIRY

To,

No. HWW/ OUT/ 1053

DATE: - 8/8/24

Sub: Supply of HT bushing boots for HT termination at Valak Intakewell and Frechwell 1 & 2 of Surat Municipal Corporation.

Dear Sir,

Sealed quotations, duly super scribed and returnable to the office of the undersigned are invited for the followings: -

Description	Qty.	Rate in Rupees	Total Amount in Rupees
1 Supply HT bushing boots for HT terminations at Valak Intakewell and Frenchwell 1 & 2	16 sets		
		Total in Figures.	

Terms/conditions of quotation

* Work completion period:	15 Days from the date of work order.
* EMD Details:	Quotation must have Earnest Money Deposit of Rs. 1,000/- by Banker's Cheque, Pay order or Demand Draft, payable at Surat in favour of Surat Municipal Corporation. Quotation without Earnest Money Deposit will not be considered.
* All Taxes/ Duties etc.:	The rates should be inclusive of all taxes, GST, duties etc.
* FOR:	Valak Intake well and French well 1 & 2
* Validity of quotation:	30 Days.
* Payment condition:	Payment shall be made within 30 days, after satisfactory receiving material at site and submission of bill /invoice.
* Scope of work :	1. Supply of HT insulating Boots for HT termination to give phase to phase and phase to earth insulation in 22 kV HT switchgears and transformers. 2. Boots shall have dielectric strength of min 35 kV for 5 min. 3. The size of boots must be minimum 230 mm length, 22 mm ID on cable entry side and 50 mm ID on bushing entry side. Bushing Boots shall be made from elastomeric insulating material having good dielectric properties and suitable for high humidity area.
* Fulfilment of this condition is must or else the quotation shall be liable for outright rejection.	
* Rates must be filled in this quotation paper only and returned duly sealed & signed on or before Dt. 22/08/2024 to the office of Executive Engineer, Head Water Works, Surat Municipal Corporation.	
* Quotation envelope containing EMD, duly filled, signed and stamped quotation paper along with price quotation format on company's letter head should be properly sealed and super scribed as "Quotations for Supply of HT bushing boots for HT termination at Valak Intakewell and Frechwell 1 & 2".	

Thanking You,

Executive Engineer
Head Water Works
Surat Municipal Corporation

SEAL & SIGNATURE OF CONTRACTOR