

## ભાવ પત્રક (ત્રીજો પ્રયાસ)

પ્રતિ,

.....  
.....  
.....

સા.ઈ.ઝોન-ટેક/નં. ૧૧૦૮  
તા. ૨૫ / ૦૫ / ૨૦૨૬

**વિષય:**— સાઉથ ઈસ્ટ ઝોન (લિંબાયત)ના પાર્ટ - ૧ કાર્યક્ષેત્રમાં આવેલ વિવિધ મ્યુની. મિલ્કતો ખાતે સ્થાપિત UPS સીસ્ટમના એન્યુઅલ મેઈન્ટેનન્સ કોન્ટ્રાક્ટ (AMC) મરામત તથા નિભાવની કામગીરી બે વર્ષ માટે કરવા તથા જરૂરીયાત મુજબ બેટરી રીપ્લેસમેન્ટની કામગીરી બે વર્ષ માટે ભાવ મંજૂર કરવા અર્થે ભાવ આપવા બાબત. (ત્રીજો પ્રયાસ)

**સંદર્ભ:**—૧) માન. ડે. મ્યુની.કમિશનરશ્રીની તા.૧૭/ ૦૪ /૨૦૨૬ ના રોજની મંજૂરી

મહાશય,

ઉપરોક્ત સંદર્ભને આધિન સાઉથ ઈસ્ટ ઝોન (લિંબાયત)ના પાર્ટ - ૧ કાર્યક્ષેત્રમાં આવેલ વિવિધ મ્યુની. મિલ્કતો ખાતે સ્થાપિત UPS સીસ્ટમના એન્યુઅલ મેઈન્ટેનન્સ કોન્ટ્રાક્ટ (AMC) મરામત તથા નિભાવની કામગીરી બે વર્ષ માટે અને બેટરી રીપ્લેસમેન્ટની કામગીરી કરાવવા અર્થે ભવિષ્યમાં મેઈન્ટેનન્સમાં લેવા જોગ UPS સીસ્ટમની વધ/ઘટની ગણતરી રાખી, કુલ્લે રૂ.૨,૦૦,૦૦૦/- (તમામ વેરા સહિત) ની મર્યાદામાં અથવા વર્ક ઓર્ડર મળ્યેથી ૨ (બે) વર્ષ સુધીમાં જે વહેલા પુર્ણ થાય તે મુજબ કામગીરી કરવા ઓન લાઈન ભાવપત્રક ત્રીજા પ્રયાસે બંધ કવરમાં મંગાવવામાં આવે છે.

**નોંધ:**—

- યુ.પી.એસ.બેટરી રીપ્લેમેન્ટ અંગે એનેક્ષર-બી મુજબના ફક્ત ભાવ મંજૂર કરાવવામાં આવશે. જરૂરીયાત પ્રમાણે બેટરી રીપ્લેસમેન્ટના કામે જરૂર જણાયેથી ઈજારદારને અલગથી ઓર્ડર ઈસ્યુ કરી કામગીરી કરાવવામાં આવશે.
- આ કામે મંજૂર રકમના ૨.૫૦ % સિક્યુરીટી ડીપોઝીટ ભરપાઈ કરવાની રહેશે. તથા આ કામે સંલગ્ન જરૂરી એગ્રીમેન્ટની કાર્યવાહી કરવાની રહેશે.
- બીડરે સ્થળ તપાસ કરી મ્યુની. મિલ્કતો ખાતે સ્થાપિત હયાત UPS સીસ્ટમ કન્ડીશનની ચકાસણી કરી ભાવ ભરવાના રહેશે.
- ભાવપત્રકના ટર્મ્સ એન્ડ કન્ડીશન મુજબના તમામ ડોક્યુમેન્ટસ અને ભરવામાં આવેલ ભાવો સહિતનું ફક્ત પ્રાઈસ શિડયુલ કવર-૨ માં રજૂ કરવાના રહેશે.
- બંધ કવર-૧ માં ટેકનીકલ દસ્તાવેજો ડ્રાફ્ટ મુકવાના રહેશે. અને કવર ૧ ઉપર ટેકનીકલ દસ્તાવેજો એવુ જણાવવાનું રહેશે.
- બંધ કવર-૨ માં માત્ર ભાવપત્રક જોડવાનું રહેશે. જેમાં બંધ કવર-૨ ઉપર ભરેલ ભાવની વિગત એવુ જણાવવાનું રહેશે.
- આ બંને કવરો (કવર-૧ અને કવર-૨) કવર-૩ માં મુકી બંધ કરી કવર પર કામનું નામ લખી સમય મર્યાદામાં જમા કરાવવાના રહેશે.

વધુમાં ભાવપત્રક પર સહી સિક્કા સહિત તા. ૧૦ / ૦૬ / ૨૦૨૬ સુધીમાં સાઉથ ઈસ્ટ ઝોન કચેરી ખાતે નીચે સહી કરનારને મળે તે રીતે પહોંચતું કરશો. સમય મર્યાદા બાદ આવેલ ભાવપત્રકને ધ્યાને લેવામાં આવશે નહીં જેની નોંધ લેશો.

SD

કાર્યપાલક ઈજનેર  
સાઉથ ઈસ્ટ ઝોન(લિંબાયત)  
સુરત મહાનગરપાલિકા

બિડાણ:—શિડયુલ-બી (એનેક્ષર-એ એન બી)

SURAT MUNICIPAL CORPORATION							
SOUTH EAST ZONE							
LIGHT DEPARTMENT PART-1							
NAME OF WORK- ANNUAL MAINTENANCE CONTRACT FOR VARIES CAPACITIES OF OF UPS & INVERTOR SETS INSTALLES AT VARIOUS MUNICIPAL BUILDING IN SOUTH EAST ZONE FOR 2 YEARS (3rd Attempt)							
ANNEXURE-A							
S.No.	LOCATION	UPS CAPACITY IN KVA	MAKE	TOTAL QTY.	RATE/ MONTH	MONTH	AMOUNT WITH GST (FOR 12 MONTH)
1	ZONE OFFICE SERVER ROOM	5	AZ Electronics	5		12	
2	ZONE OFFICE SERVER ROOM	10	AZ Electronics	1		12	
3	ZONE OFFICE SERVER ROOM	3	Numeric (ONFINITI)	1		12	
4	DEVADH CIVIC CENTRE	1	HNux - 11	1		12	
5	UMARWADA HEALTH CENTRE	1.5	Luminous	1		12	
6	BHATHENA HEALTH CENTRE	1.5	Luminous	1		12	
7	ANJNA HEALTH CENTRE	1.5	Luminous	1		12	
8	PARVAT HEALTH CENTRE	1.5	Luminous	2		12	
9	KUMBHARIYA WARD OFFICE/CIVIC CENTRE	1.5	Luminous	1		12	
<b>TOTAL AMOUNT WITH GST FOR ONE YEAR IN Rs.</b>							
<b>TOTAL AMOUNT WITH GST FOR TWO YEAR IN Rs.</b>							
ANNEXURE-B							
S.NO.	DESCRIPTION	UNIT	QTY	UNIT/ RATE (INCL. ALL TAX)			
a	Supply & Installation of 12V/7AH SMF Battery	No.	1				
b	Supply & Installation of 12V/18AH SMF Battery	No.	1				
c	Supply & Installation of 12V/26AH SMF Battery	No.	1				
d	Supply & Installation of 12V/42AH SMF Battery	No.	1				
e	Supply & Installation of 12V/65AH SMF Battery	No.	1				
f	Supply & Installation of 12V/150 AH SMF Battery	No.	1				
g	Supply & Installation of 12V/200AH SMF Battery	No.	1				

**Note :-** {1} Above Items Quantity & Capacity will be vary as per site & DFL Period  
{2} Work Shall be carried out limit of Rs.2,00,000/- (With GST) OR 2 Year Time limit

## Penalty Criteria

- Complain for U.P.S should be attended within 02 hrs. of intimation for any issue. U.P.S. within 02 Days shall be repaired of breakdown. Otherwise, penalty at the rate of Rs.200/- per day delayed will be charged for delay. Further, if the UPS problem does not resolve after 05 days than penalty will be 500/- per day from 6th day shall be considered up to 10 days.
- If contractor fails to repair U.P.S. after 10 days than SMC shall carry out the work at risk & cost of contractor, and expense incurred for completing the work plus penalty of Rs. 4,000/- per machine shall be levied from bill.
- Before one month of end of the contract, a survey will be carried out by the contractor along with the engineer in charge or the new contractor at the site and all missing/faulty accessories and parts will be replaced/repared by the contractor at free of cost. If not done the same will be carried out through new contractor and the cost of the same will be recovered from old contractor.
- If routine maintenance of all the machines is not carried out as per schedule, then SMC shall carry out the work at risk & cost of contractor, and expense incurred for completing the work plus penalty of Rs. 2000/- shall be levied for a bill period and the contract will be terminated at any time without any failure to complain & terms and condition of this quotation.
- Contractor will have to prepare UPS wise History cards. After servicing, overhauling of the machine signature of authorized personal from concerned department or light department shall have to be obtained on such cards.
- After regular checking of battery backup time it is found to replace of battery set than it shall be of AMARON, LUMINOUS, ROCKET, EXIDE make having same capacity of battery having Absorbent Glass Mat (AGM) Technology, ABS Plastic & Flame Retardant Container. For the same extra payment shall be made after satisfactory work completed and submission of bill in duplicate. The contractor shall provide 1 year guarantee to SMC. Further, any additional guarantee provided by battery manufacturer shall be availed to SMC.

**SD**  
**EXECUTIVE ENGINEER**  
**SOUTH EAST ZONE**  
**SURAT MUNICIPAL CORPORATION**

**I/We understood this work & agree to do work as per above Penalty Criteria & rate Write in Schedule-B.**

**SEAL & SIGN OF CONTRACTOR/AGENCY**